

Annexure - C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 16/9/26

It is certified that an inspection team headed by Dr. A.K. Dubey
DCMO (Name of Officers with designation) from Public Health Department PHED inspected the **THE ARYAN INTERNATIONAL SCHOOL, ALINAGAR, BYPASS ROAD, NH 19, OPPOSITE GULLI PANDEY POKHARA, NEAR GODHANA CHAURAH, CHANDAULI - 232101** on 10TH September 2026 and on the basis of Water Test Report (Attached) bearing -

URL No. **TC17045260000084F** dated 07th September 2026 of **DLWAL UP Jal Nigam (Rural), Chandauli** certified that the **THE ARYAN INTERNATIONAL SCHOOL, ALINAGAR** has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 1 year

Signature with Seal : [Signature]
Name : अपर मुख्य चिकित्सा अधिकारी
Designation : चन्दौली
Name & Address of the Office / Department :

To
The Manager
The Aryan International School
Alinagar, Bypass Road, NH 19,
Opposite Gulli Pandey Pokhara,
Near Godhana Chauraha,
Chandauli, U.P. – 232101.

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Cug No. 9473942683
eeedchandauli170@gmail.com

उत्तर प्रदेश जल निगम (ग्रामीण)

कार्यालय अधिशासी अभियन्ता, खण्ड कार्यालय, उ०प्र० जल निगम(ग्रामीण)–चन्दौली।

पत्रांक 6826 / जल परीक्षण / 46 दिनांक 08.09.26

सेवा में,

प्रबंधक/सक्षम प्राधिकारी,
डी आर्यन इंटरनेशनल स्कूल,
मुगलसराय, निकट गोधना चौराहा,
बाई-पास रोड, जनपद- चन्दौली,


विषय:-जल नमूने की भौतिक, रसायनिक और सुक्ष्मजीव विज्ञानिक विश्लेषण रिपोर्ट जारी करने के सम्बन्ध में।

महोदय,

उपरोक्त विषयक अवगत कराना है कि आपके द्वारा उपलब्ध कराये गये 01 नग जल नमूना का जल परीक्षण कर रिपोर्ट आपके आवश्यक कार्यवाही हेतु प्रेषित है।

संलग्नक:- उपरोक्तानुसार।

भवदीय,


(विवेक कुमार)
अधिशासी अभियन्ता



District Level Water Analysis Laboratory
U.P. Jal Nigam (Rural), Chandauli
Vyas Nagar Water Work Campus
Village- Mahawalpur, Post-Dulahipur, Chandauli-232101



TC-17045

Water Analysis report

Report Number

CHA/Sept. 26/01

Date: 07/09/2026

Page No. 1

URL No.

TC17045260000084F

Customer Details

Office Name and Addressed

M/s THE ARYAN INTERNATIONAL SCHOOL, Mughalsarai (PDDU Nagar), Alinagar, Bypass Road, Chandauli-232101.

Ref. Letter No. & Date

TAIS-A108/2026-27; Date: 07/09/2026

Basic Details of Sample

District	Chandauli	Block	Niyamatabad
Gram Panchayat / Nagar	D D U Nagar, Mughalsarai	Village / NPP	Godhana Chauraha
Habitation	Godhana Chauraha	Location	School Campus
Water Source	Submersible	Sample Code	CHA/Sept.26/01
Quantity of Sample	1000 ml	Date of Sample Collection	31/08/2026
Receiving Date	31/08/2026	Sample Collector	Mr. Balbir
Sample Depositor	Mr. Balbir	Sampling Method Used	NA
Latitude (N)	-	Longitude (E)	-
Analysis Start Date	06/09/2026	Analysis Completion Date	07/09/2026

Environmental Condition

Temperature	25±3 °C	Humidity	50±15%
-------------	---------	----------	--------

Technical Data of Analysis

S. No.	Analysis Parameter	Units	Observed Value	Specified Value as per BIS 10500:2012 (Second Revision)		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	Taste	-	Agreeable	Agreeable/Not Agreeable	Agreeable/Not Agreeable	IS 3025 (Part 8): 2023
2	Odour	-	Agreeable	Agreeable/Not Agreeable	Agreeable/Not Agreeable	IS 3025 (Part 5): 2018
3	Colour	ITU	8.00	5	15	IS 3025 (Part 4): 2021 (Platinum Cobalt Visual Comparison Method)
4	Turbidity	(NTU)	1.25	1.00	5.00	IS 3025 (Part 10): 2023 (Nephelometric Method)
5	pH	-	7.38	6.5-8.5	No Relaxation	IS 3025 (Part 11): 2022 (Electrode Method)
6	TDS	(mg/L)	286	500	2000	IS 3025 (Part 16): 2023 (Gravimetric Method)
7	Chloride	(mg/L)	24	250	1000	IS 3025 (Part 32): 1988 (Argentometric Method)
8	Fluoride	(mg/L)	0.21	1.0	1.5	APHA 24 th Edition-4500- F Method C (Electrode Method), 2023
9	Sulphate	(mg/L)	3.67	200	400	APHA 24 th Edition-4500- SO4 Method E (Turbidimetric Method), 2023
10	Nitrate	(mg/L)	1.94	45	No Relaxation	APHA 24 th Edition-4500- NO3 Method B (UV Screening Method), 2023
11	Iron	(mg/L)	0.24	1.00	No Relaxation	APHA 24 th Edition-3500- Fe Method B (Phenanthroline Method), 2023
12	Total Hardness	(mg/L)	148.00	200	600	IS 3025 (Part 21): 2009 (EDTA Method)
13	Total Alkalinity	(mg/L)	156.00	200	600	IS 3025 (Part 23): 2023 (Indicator Method)
14	Total Arsenic	(mg/L)	0.00	0.01	No Relaxation	APHA 24 th Edition-3500 Method B (SDDC Method), 2023
15	Calcium	(mg/L)	11.20	75	200	IS 3025 (Part 40): 2024 (EDTA Method)
16	Magnesium	(mg/L)	28.80	30	100	IS 3025 (Part 46): 2024 (Volumetric Method)

- Note
1. This Certificate refers only to the particular sample(s) submitted for testing.
 2. This Certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
 3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
 4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of test reports unless otherwise specified.
 5. Parameters above permissible limit are written in Bold.
 6. Sample is not collected by lab.

Manish Kumar

Manish Kumar
Report prepared by

Shaharaj Ali

Shaharaj Ali
Review by

Dheeraj Tripathi

(Dheeraj Kumar Tripathi)
Authorized Signatory



*****END OF THE REPORT*****



Scanned with OKEN Scanner



District Level Water Analysis Laboratory
U.P. Jal Nigam (Rural), Chandauli
Vyas Nagar Water Work Campus
Village- Mahawalpur, Post-Dulahipur, Chandauli-
232101

Water Analysis report

Report Number
URL No.

CHA/Sept. 26/01

Date: 07/09/2026

Page No. 2

Customer Details

Office Name and Addressed

M/s THE ARYAN INTERNATIONAL SCHOOL, Mughalsarai (PDDU Nagar), Alinagar, Bypass Road, Chandauli-232101.

Ref. Letter No. & Date

TAIS-A108/2026-27; Date: 07/09/2026

Basic Details of Sample

District	Chandauli	Block	Niyamatabad
Gram Panchayat / Nagar	D D U Nagar, Mughalsarai	Village / NPP	Alinagar
Habitation	Godhana Chauraha	Location	School Campus
Water Source	Submersible	Sample Code	CHA/Sept.26/01
Quantity of Sample	250 ml	Date of Sample Collection	31/08/2026
Receiving Date	31/08/2026	Sample Collector	Mr. Balbir
Sample Depositor	Mr. Balbir	Sampling Method Used	NA
Latitude (N)	-	Longitude (E)	-
Analysis Start Date	06/09/2026	Analysis Completion Date	07/09/2026

Environmental Condition

Temperature	25±3 °C	Humidity	50±15%
-------------	---------	----------	--------

Technical Data of Analysis

S. No.	Analysis Parameter	Units	Observed Value	Specified Value as per BIS 10500:2012 (Second Revision)		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1.	Total coliform	CFU	0.00	Shall not be detectable in any 100ml sample	Agreeable/Not Agreeable	APHA 24 th Edition-2023
2.	E.coli	CFU	0.00	Shall not be detectable in any 100ml sample	Agreeable/Not Agreeable	APHA 24 th Edition-2023

Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This Certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of test reports unless otherwise specified.
5. Parameters above permissible limit are written in Bold.
6. Sample is not collected by lab.

Prakhar Singh

Prakhar Singh
Report prepared by

Dheeraj Tripathi

(Dheeraj Kumar Tripathi)
Authorized Signatory



*****END OF THE REPORT*****

